



- General Notes
1. Reinforcement Steel Conforms to:  
ASTM A615 Grade 60
  2. Concrete:  $f_c = 5,000$  psi @ 28 Days Minimum
  3. Butyl Rubber Joint Sealant Provided

34.5 or 12.5 KV  
75 to 500 KVA

**Est Weights:**  
Top Slab - 6,900 Lbs  
Base - 8,300 Lbs  
Total Weight: 15,200 Lbs

**Phoenix  
Precast  
Products**

Central Vermont  
Public Service Corp  
2130 3-Phase Transformer  
Pad And Pit