Note: Dimensions Typical For Both Tanks

6" Typ

9'-6"

Useful

Capacity

Cistern Tank #2

## **Foundation And Backfill Notes:**

8"

11'-4"

1. Foundation Material Shall Be ¾" Crushed stone, Minimum 12" Thick, Compacted.

8

Cistern Tank #1

- 2. 1-1/2" Bank Run Gravel Shall Be Used For Backfill Operations Surrounding Tank. Backfill Shall Be Placed in Maximum 12" Loose Lifts. All Compaction Shall Be Done With Hand Operated Equipment.
- 3. Tank Excavation Shall Be Kept Dewatered Throughout Installation and Backfill Operations.
- 4. All Area Between Tanks Shall Be Filled To A Minimum Of 12" Above Crown Of Interconnection Pipe With 3/4" Crushed Stone. 1-½" Bank Run Gravel May Be Used Above This Elevation.

## **General Notes:**

1. Concrete: fc = 5,000 psi @ 28 Days Minimum Type III Cement

1-800-639-2199

- 2. Reinforcing Steel: ASTM-A615 Grade 60 Black Deformed Bars
- 3. Design Loading: AASHTO-HS20-44, ASTM C-890-06 Design Specified As: ASTM C-1227-08, ASTM C-913-08
- 4. Butyl Rubber Joint Sealant Provided
- 5. Includes Exterior Dampproofing
- 6. Detail Drawings Provided Upon Request

Phoenix 20,000 Gallon HS-20 Precast Cistern Assembly (2 Tanks) **Products** 

14'

Maximum

48" x 48"

Vortex Plate

Fax (603) 224-2927

P/N: Custom As Required

Concord, NH 03301

77 Regional Drive 21May24 Rev1 RR