



Required Dimensions	
L	
W	
H	
D1	
D2	
B.O.-L	
B.O.-W	

General Notes

1. Concrete:  $f_c = 4,000$  psi @ 28 Days Minimum
2. Steel Reinforcement Conforms to Latest ASTM Specification:  
ASTM A-615, Grade 60 Black Deformed Bars

Phoenix  
Precast  
Products

Custom  
Generator Pad

P/N: Custom As Required  
Concord, NH 03301