



Required Dimensions	
L	
W	
H	
D1	
D2	
D3	
B.O.-L	
B.O.-W	

General Notes

1. Concrete: $f_c = 5,000$ psi @ 28 Days Minimum
2. Reinforcing Steel Conforms to Latest ASTM Specification:
ASTM-A615, Grade 60 Black Deformed Bars

Phoenix
Precast
Products

Custom
Transformer Pad

P/N: Custom As Required

Concord, NH 03301