



- General Notes**
1. Steel Reinforcement Conforms to Latest ASTM Specification:
 ASTM A-615, Grade 60 Black Deformed Bars
 ASTM A-185 Welded Wire Fabric
 0.12 Sq. In./Lineal Ft. And 0.12 Sq. In.(Both Ways) Base Bottom
 2. Concrete: $f_c = 4,000$ psi @ 28 Days Minimum, Type III Cement
 3. Butyl Rubber Joint Sealant Provided Conforms to ASTM C-990
 And Federal Spec SS-S-210A
 4. HS-20 Design Loading Conforms to Latest Specifications
 ASTM C478, AASHTO M199 Precast Reinforced Concrete
 Manhole Sections
 5. One Pour Monolithic Base Section

<p>Phoenix Precast Products</p>	<p>Standard 4' Diameter Outlet Control Structure With Peaked Bar Top Grate And Ballast-Filled Sump</p>
--	--

P/N: Custom As Required
Concord, NH 03301