



General Notes

1. Steel Reinforcement Conforms to Latest ASTM Specification: ASTM A-615, Grade 60 Black Deformed Bars
2. Concrete: $f_c = 5,000$ psi @ 28 Days Minimum, Type III Cement
3. Butyl Rubber Joint Sealant Provided Conforms to ASTM C-990 And Federal Spec SS-S-210A
4. HS-20 Design Loading Conforms to Latest Specifications ASTM C478, AASHTO M199 Precast Reinforced Concrete Manhole Sections
5. Design Specification: per Latest ASTM C-857 & C858
6. Meets or Exceeds PSNH Standards

Est Weights:

Qty (2) P/N: PSNH-MHSECTCVR	Cover (Each)-	675 Lbs
Qty (1) P/N: PSNH-MHSECTBX	Base -	6,500 Lbs
	Total:	7,850 Lbs

Phoenix
Precast
Products

PSNH Manhole &
Switchgear Foundation
Assembly

P/N: PSNH-MHSGFA

Concord, NH 03301